

The manufacturer

ZETKAMA Spółka Akcyjna
ul. 3 Maja 12
57-410 Ścinawka Średnia
www.zetkama.com.pl

**Declaration of conformity
According to Directive 97/23/EC
for a pressure equipment**

We hereby declare that check valves listed below correspond to the Pressure Equipment Directive 97/23/EC

Type	Figure No. Connecting ends Shape	Material of Body	Nominal Diameter DN(mm)	Nominal Pressure PN(MPa)	Range of Working Temperature (°C)
Lift Type	287 Flanged ends Straight Pattern	Grey cast iron EN-GJL250	32 ÷ 300	1,6	-10 ÷ 300
		Nodular cast iron EN-GJS400-18-LT	32 ÷ 200	1,6	-10 ÷ 350
				2,5	-10 ÷ 350
	Cast steel GP240GH	32 ÷ 200	4,0	-20 ÷ 400	
	288 Flanged ends Angle Pattern	Grey cast iron EN-GJL250	32 ÷ 300	1,6	-10 ÷ 300
		Nodular cast iron EN-GJS400-18-LT	32 ÷ 200	1,6	-10 ÷ 350
				2,5	
277 Screwed ends Straight Pattern	Grey cast iron EN GJL250	32 ÷ 50	1,6	-10 ÷ 200	
Swing Type	302 Flanged ends	Grey cast iron EN GJL250	40 ÷ 300	1,6	-10 ÷ 300

Applied conformity assessment procedure: module H

Applied standards and technical specifications:

- | | |
|--------------|----------------|
| 1. EN-19 | 7. EN-10213-2 |
| 2. EN-558-1 | 8. EN-12266-1 |
| 3. EN-1561 | 9. EN-12266-2 |
| 4. EN-1563 | 10. EN-12334 |
| 5. EN-1092-1 | 11. EN-12516-3 |
| 6. EN-1092-2 | |

Engaged Notified Body

Bureau Veritas
67/71 Boulevard de Chateau
92200 Neuilly-sur-Seine
France
Bureau Veritas No. 0062

Surveillance of the Quality Systems – Examination, inspections and tests during manufacturing
EC – Certificate of conformity N° CE-PED-H-ZKM 001-10-POL

Declaration of conformity N° 5/10/2010

President of Board
General Director



Leszek Jurasz